
[illegible][illegible]

BAS GENERAL NOTES:

- A. UNLESS SPECIFIED OTHERWISE, ALL COMPONENTS SHALL BE PROVIDED BY THE CONTROLS CONTRACTOR.
- B. THIS DIAGRAM IS PROVIDED AS A GUIDE ONLY. QUANTITIES INDICATED ON SCHEMATIC DO NOT REPRESENT ACTUAL PROJECT REQUIREMENTS. A COMPLETE SYSTEM ARCHITECTURE DIAGRAM SHALL BE SUBMITTED BY THE CONTRACTOR BASED ON THE MANUFACTURERS RECOMMENDED LAYOUT.
- C. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL CONDUIT INSIDE THE BUILDING. THE CONTROLS CONTRACTOR SHALL BE RESPONSIBLE FOR ALL LOW VOLTAGE WIRING AS NECESSARY FOR A COMPLETE SYSTEM INSTALLATION.

BUILDING AUTOMATIC SYSTEM ARCHITECTURE DIAGRAM

2 VAV TERMINAL WITH REHEAT CONTROL SCHEMATIC & POINTS LIST

GROUND LEVEL EXHAUST FAN
SCHEMATIC & POINTS LIST

95% SUBMISSION

REVISIONS	DATE

CSHQA

C.W. MOORE PLAZA
290 S. 5TH ST. - FLOOR 10 83702
(208) 343-4635 • FAX (208) 343-4688
<http://www.cshqa.com>

HICK M. PETERSON, P.E.
VICE PRESIDENT
200 S. 5TH ST. FLOOR 10
BOISE, IDAHO
PHONE: (208) 343-4635 FAX: (208) 343-4688

OF THESE DOCUMENTS AND THE INFORMATION CONTAINED HEREIN, THE USER AGREES TO HOLD THE ENGINEER AND ENGINEERING FIRM HARMLESS FROM AND TO INDEMNIFY THE ENGINEER AND ENGINEERING FIRM AGAINST ALL SUCH DAMAGES, LOSSES AND EXPENSES, INCLUDING REASONABLE ATTORNEY'S FEES, THAT MAY BE INCURRED BY THE ENGINEER AND ENGINEERING FIRM AS A RESULT OF THE USER'S NEGLIGENCE OR MISFEASANCE. THE USER'S OBLIGATION TO INDEMNIFY THE ENGINEER AND ENGINEERING FIRM SHALL NOT BE LIMITED BY ANY LIMIT ON THE AMOUNT OR TYPE OF DAMAGES THAT MAY BE AWARDED BY A COURT OF LAW.

STAMP

PRELIMINARY
NOT FOR
CONSTRUCTION

DRAWING TITLE CONTROLS SCHEMATIC	APPROVED: DIVISION CHIEF	APPROVED: SERVICE DIRECTOR
--	--------------------------	----------------------------

PROJECT TITLE	VAMC ENERGY UPGRADES PHASE ONE BUILDING 33		
BUILDING NUMBER	33	CHECKED RME	DRAWN RME
LOCATION	BOISE, IDAHO		

DATE 03/03/11	PROJECT NO. 531-10-114	DRAWING NO. M3.4	OWS 22 OF 32
------------------	---------------------------	---------------------	--------------

